



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 2435**

**Customer**

Facility Name: *Trellis North Fayette*  
Address: *1500 Park Lane Drive*  
*Pittsburgh, PA 15275*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *7/29/25*  
Time: *10:40 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *8/1/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/29/25	10:40 AM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/29/25	10:40 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	10:40 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 2435**

**Customer**

Facility Name: Trellis North Fayette  
Address: 1500 Park Lane Drive  
Pittsburgh, PA 15275

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/29/25  
Time: 10:40 AM  
Method: Grab

**Sample Final Analysis**

Date: 8/1/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/29/25	10:40 AM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/29/25	10:40 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	10:40 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)



Andre Smith, Lead Supervisor