



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2651

Customer

*American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237*

Sample Collection

Facility Name: Courtyards at Windsor Woods Clubhouse

Date: 8/5/25

*Address: 4000 Sir James Dr.
McDonald, PA 15057*

Time: 2:54 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 8/8/25

Source Type: Pool

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 2:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 2:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25 5:40 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25 2:54 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25 2:54 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25 2:54 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2651

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Courtyards at Windsor Woods Clubhouse

Date: 8/5/25

Address: 4000 Sir James Dr.
McDonald, PA 15057

Time: 2:54 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 8/8/25

Source Type: Pool

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	2:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	2:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	2:54 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	2:54 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	2:54 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor