



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 366

Customer

Facility Name: YMCA - Thelma Lovette

Address: 2114 Centre Ave
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 10/21/25

Time: 11:35 AM

Method: Grab

Sample Final Analysis

Date: 10/24/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/22/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/22/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/21/25	4:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	10/21/25	11:35 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/21/25	11:35 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/21/25	11:35 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor