



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 091

Customer

Facility Name: Doubletree Hotel
Address: 101 Doubletree Dr.
Pittsburgh, PA 15205

Sample Collection

Date: 10/15/25
Time: 10:22 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 10/17/25
Time: 6:00 PM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 10/15/25 | 5:40 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/15/25 | 5:40 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/15/25 | 5:20 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 10/15/25 | 10:22 AM | MM | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 10/15/25 | 10:22 AM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/15/25 | 10:22 AM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor