



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 162**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *3695 State Rd, RT 31*  
*Donegal, PA 15628*

**Sample Collection**

**Date:** *7/7/25*  
**Time:** *9:51 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*  
**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *7/10/25*  
**Time:** *9:30 AM*  
**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	9:51 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/7/25	9:51 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	9:51 AM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 162**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *3695 State Rd, RT 31*  
*Donegal, PA 15628*

**Sample Collection**

**Date:** *7/7/25*  
**Time:** *9:51 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*  
**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *7/10/25*  
**Time:** *9:30 AM*  
**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/8/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	4:45 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	9:51 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/7/25	9:51 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	9:51 AM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor