



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 365

Customer

Facility Name: YMCA - Sewickley

Address: 625 Blackburn Rd.
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 11/10/25
Time: 11:22 AM
Method: Grab

Sample Final Analysis

Date: 11/13/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	11/11/25 9:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/11/25 9:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/10/25 5:10 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	11/11/25 10:30 AM	SL	SM 9230C
---------------------	----------	----------	-------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.0 SU	7.2 - 7.8 SU	11/10/25 11:22 AM	AMH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	11/10/25 11:22 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/10/25 11:22 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)