

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2032

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Bear Run Village

Address: 100 Bear Run Drive

Pittsburgh, PA 15237

Matrix: Recreational Water

Results

Source Type: Pool

Accredited Analysis

Sample Collection

Date: 6/10/25 Time: 12:27 PM

Method: Grab

Sample Final Analysis

Incubation Date/Time

 Date:
 6/13/25

 Time:
 9:30 AM

 Analyst:
 AS

Analyst

Method

Escherichia Coli: Absent Absent 6/11/25 11:30 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/11/25 11:30 AM AΗ SM 9222B Standard plate count: 200/ml 6/10/25 5:50 PM SL SM 9215B 0/ml **Field Analysis Results** Reporting limit Date/Time **Analyst** Method 7.8 SU 7.2 - 7.8 SU 6/10/25 12:27 PM MM DPD pH: Chlorine: 1.0 - 5.0 mg/l 6/10/25 12:27 PM MM DPD 3.0 mg/l Turbidity: 1 NTU 1 - 2 NTU 6/10/25 12:27 PM MM Visual

Reporting limit

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2032

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Bear Run Village

Address: 100 Bear Run Drive

Pittsburgh, PA 15237

Matrix: Recreational Water

Results

Source Type: Pool

Accredited Analysis

Sample Collection

Date: 6/10/25 Time: 12:27 PM

Method: Grab

Sample Final Analysis

Incubation Date/Time

 Date:
 6/13/25

 Time:
 9:30 AM

 Analyst:
 AS

Analyst

Method

Escherichia Coli: Absent Absent 6/11/25 11:30 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/11/25 11:30 AM AΗ SM 9222B Standard plate count: 200/ml 6/10/25 5:50 PM SL SM 9215B 0/ml **Field Analysis Results** Reporting limit Date/Time **Analyst** Method 7.8 SU 7.2 - 7.8 SU 6/10/25 12:27 PM MM DPD pH: Chlorine: 1.0 - 5.0 mg/l 6/10/25 12:27 PM MM DPD 3.0 mg/l Turbidity: 1 NTU 1 - 2 NTU 6/10/25 12:27 PM MM Visual

Reporting limit

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor