



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 3**

**Lab# 2317**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Laurel Village*

*Date: 6/2/25*

*Address: 1000 Penn Center Blvd.*  
*Pittsburgh, PA 15235*

*Time: 12:00 AM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 6/5/25*

*Time: 9:30 AM*

*Source Type: Shallow End*

*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/2/25	9:41 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/2/25	9:41 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	9:41 AM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 3**

**Lab# 2317**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:* *Laurel Village*

*Date:* *6/2/25*

*Address:* *1000 Penn Center Blvd.*  
*Pittsburgh, PA 15235*

*Time:* *12:00 AM*

*Method:* *Grab*

**Sample Final Analysis**

*Matrix:* *Recreational Water*

*Date:* *6/5/25*

*Time:* *9:30 AM*

*Source Type:* *Shallow End*

*Analyst:* *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/2/25	9:41 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/2/25	9:41 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	9:41 AM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor