



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Service
Laboratory Analysis Report

Lab# 379

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	PPG Paints Arena	Date:	2/16/26			
Address:	1001 Fifth Ave Pittsburgh, PA 15219	Time:	11:45 AM			
Matrix:	Recreational Water	Method:	Grab			
Source Type:	Spa	<u>Sample Final Analysis</u>				
		Date:	2/18/26			
		Time:	10:30 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	2/17/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/17/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/16/26	5:08 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Fecal Streptococcus	0/100mls	2/100mls	2/17/26	12:00 PM	SL	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	2/16/26	11:45 AM	AG	DPD
Chlorine:	4.4 mg/l	1.0 - 5.0 mg/l	2/16/26	11:45 AM	AG	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/16/26	11:45 AM	AG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)