



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2297**

**Customer**

**Facility Name:** JCC- Kaufman Park  
**Address:** 261 Rosecrest Drive  
Monroeville, PA 15146

**Sample Collection**

**Date:** 7/21/25  
**Time:** 7:58 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Shallow End

**Sample Final Analysis**

**Date:** 7/24/25  
**Time:** 10:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/22/25              | 9:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/22/25              | 9:00 AM | AH      | SM 9222B |
| Standard plate count: | 60/ml    | 200/ml          | 7/21/25              | 3:07 PM | AH      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 7/21/25   | 7:58 AM | EH      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 7/21/25   | 7:58 AM | EH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/21/25   | 7:58 AM | EH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2297**

**Customer**

**Facility Name:** JCC- Kaufman Park  
**Address:** 261 Rosecrest Drive  
Monroeville, PA 15146

**Sample Collection**

**Date:** 7/21/25  
**Time:** 7:58 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/24/25  
**Time:** 10:00 AM  
**Analyst:** AS

**Matrix:** Recreational Water

**Source Type:** Shallow End

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/22/25              | 9:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/22/25              | 9:00 AM | AH      | SM 9222B |
| Standard plate count: | 60/ml    | 200/ml          | 7/21/25              | 3:07 PM | AH      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 7/21/25   | 7:58 AM | EH      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 7/21/25   | 7:58 AM | EH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/21/25   | 7:58 AM | EH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor