



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2126

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Colony West Apts*

Address: *350 Colony West Drive*
Coraopolis, PA 15108

Sample Collection

Date: *7/7/25*
Time: *8:44 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/10/25*
Time: *9:30 AM*
Analyst: *AS*

Matrix: *Recreational Water*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/7/25	8:44 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	8:44 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	8:44 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2126

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Colony West Apts*

Address: *350 Colony West Drive*
 Coraopolis, PA 15108

Date: *7/7/25*
Time: *8:44 AM*
Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Source Type: *Pool*

Date: *7/10/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/7/25	8:44 AM	AH DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	8:44 AM	AH DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	8:44 AM	AH Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor