



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

E - 13

Lab# 2392

Customer

Facility Name: Park Swim Club
Address: College Park Dr.
Monroeville, PA 15146
Matrix: Recreational Water
Source Type: Deep End

Sample Collection

Date: 8/12/25
Time: 12:55 PM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/13/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	2:56 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/12/25	12:55 PM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/12/25	12:55 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	12:55 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

E - 13

Lab# 2392

Customer

Facility Name: Park Swim Club
Address: College Park Dr.
Monroeville, PA 15146
Matrix: Recreational Water
Source Type: Deep End

Sample Collection

Date: 8/12/25
Time: 12:55 PM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	9:30 AM	EB
Total coliforms:	0/100mls	2/100mls	8/13/25	9:30 AM	EB
Standard plate count:	0/ml	200/ml	8/12/25	2:56 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/12/25	12:55 PM	EH
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/12/25	12:55 PM	EH
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	12:55 PM	EH

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor