



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 010

Customer

Facility Name: Arsenal Middle
Address: 3900 Butler St.
Pittsburgh, PA 15201

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 7/15/25
Time: 9:36 AM
Method: Grab

Sample Final Analysis

Date: 7/18/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/16/25	10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	7/16/25	10:10 AM	EB	SM 9222B
Standard plate count:	0/ml	A	7/15/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	7/15/25	9:36 AM	SL	DPD
Chlorine:	3.0 mg/l	A	7/15/25	9:36 AM	SL	DPD
Turbidity:	1 NTU	A	7/15/25	9:36 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 010

Customer

Facility Name: Arsenal Middle
Address: 3900 Butler St.
Pittsburgh, PA 15201

Sample Collection

Date: 7/15/25
Time: 9:36 AM
Method: Grab

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Final Analysis

Date: 7/18/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/16/25	10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	7/16/25	10:10 AM	EB	SM 9222B
Standard plate count:	0/ml	A	7/15/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	7/15/25	9:36 AM	SL	DPD
Chlorine:	3.0 mg/l	A	7/15/25	9:36 AM	SL	DPD
Turbidity:	1 NTU	A	7/15/25	9:36 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor