

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM 4

Lab# 2543

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Valleybrook Swim Club
Address: 100 Callender Rd
Pittsburgh, PA 15237

Date: 6/16/25
Time: 8:41 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Deep End


Date: 6/19/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/17/25 10:40 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/17/25 10:40 AM | AH | SM 9222B |
| Standard plate count: | 20/ml | 200/ml | 6/16/25 5:45 PM | EB | SM 9215B |
| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
| pH: | 8.0 SU | 7.2 - 7.8 SU | 6/16/25 8:41 AM | MM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/16/25 8:41 AM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 8:41 AM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM 4

Lab# 2543

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Valleybrook Swim Club
Address: 100 Callender Rd
Pittsburgh, PA 15237

Date: 6/16/25
Time: 8:41 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Deep End

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/17/25 | 10:40 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/17/25 | 10:40 AM | AH | SM 9222B |
| Standard plate count: | 20/ml | 200/ml | 6/16/25 | 5:45 PM | EB | SM 9215B |
| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
| pH: | 8.0 SU | 7.2 - 7.8 SU | 6/16/25 | 8:41 AM | MM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 8:41 AM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 8:41 AM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor