



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 149

Customer

Facility Name: Hilton Garden Inn
Address: Synergy Dr.
Uniontown, PA 15401

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 1/29/26
Time: 1:45 PM
Method: Grab

Sample Final Analysis

Date: 1/31/26
Time: 5:30 PM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-----------------------|----------|----------|-----------------|----|----------|
| Escherichia Coli: | Absent | Absent | 1/29/26 5:17 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 1/29/26 5:17 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 1/29/26 5:30 PM | SL | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|-----------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 1/29/26 5:30 PM | SL | SM 9230C |
|---------------------|----------|----------|-----------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|------------|----------|----------------|-----------------|----|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 1/29/26 1:45 PM | SH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 1/29/26 1:45 PM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 1/29/26 1:45 PM | SH | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)