

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**APM 1** 

Lab# 2064

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brook Park Swim Club

Address: 8190 Rochester Rd

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Wading Pool

Sample Collection

Date: 6/4/25 Time: 5:00 PM Method: Grab

etriou. Grab

Sample Final Analysis

 Date:
 6/6/25

 Time:
 4:00 PM

 Analyst:
 AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G	
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B	
Standard plate count:	0/ml	200/ml	6/4/25	6:15 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	_
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	5:00 PM	SL	DPD	
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/4/25	5:00 PM	SL	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	5:00 PM	SL	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**APM 1** 

Lab# 2064

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brook Park Swim Club

Address: 8190 Rochester Rd

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Wading Pool

Sample Collection

Date: 6/4/25 Time: 5:00 PM Method: Grab

etriou. Grab

Sample Final Analysis

 Date:
 6/6/25

 Time:
 4:00 PM

 Analyst:
 AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G	
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B	
Standard plate count:	0/ml	200/ml	6/4/25	6:15 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	_
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	5:00 PM	SL	DPD	
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/4/25	5:00 PM	SL	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	5:00 PM	SL	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor