



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM 2

Lab# 2650

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Hemlocks*
Address: *4424 Laurel Oak D.*
Allison Park, PA 15101

Sample Collection

Date: *8/11/25*
Time: *9:27 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *8/14/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25 9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25 9:30 AM	AH	SM 9222B
Standard plate count:	20/ml	200/ml	8/11/25 4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25 9:27 AM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25 9:27 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25 9:27 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM 2

Lab# 2650

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Hemlocks*
Address: *4424 Laurel Oak D.*
Allison Park, PA 15101

Sample Collection

Date: *8/11/25*
Time: *9:27 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *8/14/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:30 AM	AH	SM 9222B
Standard plate count:	20/ml	200/ml	8/11/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	9:27 AM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	9:27 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	9:27 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor