



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 059

Customer

Facility Name: Colfax Elementary
Address: 2332 Beechwood Blvd.
Pittsburgh, PA 15217

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 10/14/25
Time: 10:03 AM
Method: Grab

Sample Final Analysis

Date: 10/17/25
Time: 10:30 AM
Analyst: AS

| Accredited Analysis | Results | Rating | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|--------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | A | 10/15/25 | 10:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | A | 10/15/25 | 10:00 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | A | 10/14/25 | 3:50 PM | SL | SM 9215B |

| Field Analysis | Results | Rating | Date/Time | | Analyst | Method |
|----------------|----------|--------|-----------|----------|---------|--------|
| pH: | 7.7 SU | B | 10/14/25 | 10:03 AM | MM | DPD |
| Chlorine: | 3.0 mg/l | A | 10/14/25 | 10:03 AM | MM | DPD |
| Turbidity: | 1 NTU | A | 10/14/25 | 10:03 AM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor