

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

....

N-13

Lab ID No. 02-04041

Lab# 246

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Oxford Athletic Date: 7/29/25
Time: 1:41 PM

Address: 100 Village Club Dr. Method: Grab Wexford, PA 15090

Matrix: Recreational Water Sample Final Analysis

Date: 8/1/25

Source Type: Shallow End Time: 9:00 AM Analyst: AS

Accredited Analysis Results Reporting limit Incubation Date/Time **Analyst** Method Escherichia Coli: Absent Absent 7/30/25 10:00 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 7/30/25 10:00 AM EΒ SM 9222B 200/ml Standard plate count: 0/ml 7/29/25 4:00 PM AΗ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	7/29/25	1:41 PM	MM	DPD	
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/29/25	1:41 PM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	1:41 PM	MM	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

....

N-13

Lab ID No. 02-04041

Lab# 246

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Oxford Athletic Date: 7/29/25
Time: 1:41 PM

Address: 100 Village Club Dr. Method: Grab Wexford, PA 15090

Matrix: Recreational Water Sample Final Analysis

Date: 8/1/25

Source Type: Shallow End Time: 9:00 AM Analyst: AS

Accredited Analysis Results Reporting limit Incubation Date/Time **Analyst** Method Escherichia Coli: Absent Absent 7/30/25 10:00 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 7/30/25 10:00 AM EΒ SM 9222B 200/ml Standard plate count: 0/ml 7/29/25 4:00 PM AΗ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	7/29/25	1:41 PM	MM	DPD	
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/29/25	1:41 PM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	1:41 PM	MM	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor