



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 074

Customer

Facility Name: Courtyard by Marriott
Address: 401 West Waterfront Dr.
West Homestead, PA 15120

Sample Collection

Date: 9/15/25
Time: 7:15 AM
Method: Grab

Matrix: Recreational Water

Source Type: Spa

Sample Final Analysis

Date: 9/18/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Escherichia Coli:	Absent	Absent	9/16/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/15/25	4:45 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/16/25	10:20 AM	JC	SM 9230C
---------------------	----------	----------	---------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	9/15/25	7:15 AM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/15/25	7:15 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/15/25	7:15 AM	SH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor