

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

N-13

Lab ID No. 02-04041

Lab# 245

6/19/25

EΒ

SM 9215B

Sample Final Analysis

Date:

5:45 PM

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Oxford Athletic Date: 6/16/25

Address: 100 Village Club Dr. Time: 2:33 PM

Method: Grab

Wexford, PA 15090

0/ml

Matrix: Recreational Water

Time: 10:00 AM
Source Type: Deep End Analyst: AS

200/ml

Accredited Analysis Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 6/17/25 10:40 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/17/25 10:40 AM AΗ SM 9222B

6/16/25

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 6/16/25 | 2:33 PM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 2:33 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 2:33 PM | MM | Visual |

Sample comments

Standard plate count:

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

N-13

Lab ID No. 02-04041

Lab# 245

6/19/25

EΒ

SM 9215B

Sample Final Analysis

Date:

5:45 PM

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Oxford Athletic Date: 6/16/25

Address: 100 Village Club Dr. Time: 2:33 PM

Method: Grab

Wexford, PA 15090

0/ml

Matrix: Recreational Water

Time: 10:00 AM
Source Type: Deep End Analyst: AS

200/ml

Accredited Analysis Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 6/17/25 10:40 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/17/25 10:40 AM AΗ SM 9222B

6/16/25

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 6/16/25 | 2:33 PM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 2:33 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 2:33 PM | MM | Visual |

Sample comments

Standard plate count:

andre Smith

(When exceeding reporting limit pool or spa is unfit)