



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2450

Customer

Facility Name: *Rodgers-McFeely*

Address: *910 Jefferson Street*
Latrobe, PA 15650

Sample Collection

Date: *6/2/25*
Time: *2:23 PM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Baby Pool*

Sample Final Analysis

Date: *6/5/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	2:23 PM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/2/25	2:23 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	2:23 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2450

Customer

Facility Name: *Rodgers-McFeely*

Address: *910 Jefferson Street*
Latrobe, PA 15650

Sample Collection

Date: *6/2/25*
Time: *2:23 PM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *6/5/25*
Time: *9:30 AM*
Analyst: *AS*

Source Type: *Baby Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	2:23 PM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/2/25	2:23 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	2:23 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor