



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2160

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Eagle Ridge

Date: 7/21/25

Address: 1500 Eagle Ridge Dr.
Monroeville, PA 15146

Time: 7:15 AM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 7/24/25

Source Type: Pool

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	3:07 PM	AH	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/21/25	7:15 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/21/25	7:15 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	7:15 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2160

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Eagle Ridge

Date: 7/21/25

Address: 1500 Eagle Ridge Dr.
Monroeville, PA 15146

Time: 7:15 AM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 7/24/25

Source Type: Pool

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	3:07 PM	AH	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/21/25	7:15 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/21/25	7:15 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	7:15 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor