

Dreams Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

PPS

Lab# 018

Customer

Address:

Facility Name: Baxter Building

925 Brushton Ave

Pittsburgh, PA 15208

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 9/2/25 Time: 9:06 AM

Method: Grab

Sample Final Analysis

Date: 9/5/25 Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Da	te/Time	Analyst	Method
Escherichia Coli:	Absent	Α	9/3/25	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	Α	9/3/25	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	Α	9/2/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Rating		Date/Time	Analyst	Method
pH:	7.0 SU	Е	9/2/25	9:06 AM	MM	DPD
Chlorine:	2.0 mg/l	В	9/2/25	9:06 AM	MM	DPD
Turbidity:	1 NTU	Α	9/2/25	9:06 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor