



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 129**

**Customer**

Facility Name: Hampton Inn Belle Vernon

Address: 1525 Broad Ave Ext  
Belle Vernon, PA 15012

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 2/2/26

Time: 11:10 AM

Method: Grab

**Sample Final Analysis**

Date: 2/5/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/3/26 10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/3/26 10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/2/26 4:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	2/2/26 11:10 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/2/26 11:10 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/2/26 11:10 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor