



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2416

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Moon Grove*

Address: *916 Beaver Grade Road*
Coraopolis, PA 15108

Matrix: *916 Beaver Grade Road*

Source Type: *Pool*

Sample Collection

Date: *7/21/25*

Time: *7:59 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/24/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/21/25	7:59 AM	AH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/21/25	7:59 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	7:59 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2416

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Moon Grove*

Address: *916 Beaver Grade Road*
Coraopolis, PA 15108

Matrix: *916 Beaver Grade Road*

Source Type: *Pool*

Sample Collection

Date: *7/21/25*
Time: *7:59 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/24/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/21/25	7:59 AM	AH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/21/25	7:59 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	7:59 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor