



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-16**

**Lab# 2690**

**Customer**

**Facility Name:** Pine Twp. Spray Park

**Address:** 100 Pine Park Dr.  
Wexford, PA 15090

**Matrix:** Recreational Water

**Source Type:** Spray Pad

**Sample Collection**

**Date:** 7/14/25

**Time:** 12:35 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/17/25

**Time:** 8:30 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:43 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/14/25	12:35 PM	GR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/14/25	12:35 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	12:35 PM	GR	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-16**

**Lab# 2690**

**Customer**

**Facility Name:** Pine Twp. Spray Park

**Address:** 100 Pine Park Dr.  
Wexford, PA 15090

**Matrix:** Recreational Water

**Source Type:** Spray Pad

**Sample Collection**

**Date:** 7/14/25

**Time:** 12:35 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/17/25

**Time:** 8:30 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:43 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/14/25	12:35 PM	GR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/14/25	12:35 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	12:35 PM	GR	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor