



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 290

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Springhill Suites	Date:	12/15/25			
Address:	16 Trinity Point Dr. Washington, PA 15301	Time:	9:04 AM			
					Method:	Grab
Matrix:	Recreational Water	Date:	12/18/25			
Source Type:	Pool	Time:	10:30 AM		Analyst:	AS
Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/16/25	10:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/16/25	10:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/15/25	4:45 PM	AS	SM 9215B

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
pH:	7.8 SU	7.2 - 7.8 SU	12/15/25	9:04 AM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/15/25	9:04 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/15/25	9:04 AM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)