



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 13**

**Lab# 457**

**Customer**

Facility Name: *Olympic Swim Club*  
Address: *517 Twin Oaks Dr.*  
*Pittsburgh, PA 15235*

**Sample Collection**

Date: *7/29/25*  
Time: *1:15 PM*  
Method: *Grab*

Matrix: *Recreational Water*

**Sample Final Analysis**

Date: *8/1/25*  
Time: *9:00 AM*  
Analyst: *AS*

Source Type: *Indoor Pool*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/30/25              | 9:00 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/30/25              | 9:00 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/29/25              | 3:40 PM | EB      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 7/29/25   | 1:15 PM | EH      | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 7/29/25   | 1:15 PM | EH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/29/25   | 1:15 PM | EH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 13**

**Lab# 457**

**Customer**

**Facility Name:** Olympic Swim Club  
**Address:** 517 Twin Oaks Dr.  
Pittsburgh, PA 15235

**Sample Collection**

**Date:** 7/29/25  
**Time:** 1:15 PM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 8/1/25  
**Time:** 9:00 AM  
**Analyst:** AS

**Source Type:** Indoor Pool

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/30/25              | 9:00 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/30/25              | 9:00 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/29/25              | 3:40 PM | EB      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 7/29/25   | 1:15 PM | EH      | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 7/29/25   | 1:15 PM | EH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/29/25   | 1:15 PM | EH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor