



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2395

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b>Sample Collection</b>	
Facility Name:	Parkside Estates	Date:	5/28/25
Address:	202 Ketchum Court Cannonsburg, PA 15317	Time:	3:07 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

  

		<b>Sample Final Analysis</b>	
Matrix:	Recreational Water	Date:	5/31/25
Source Type:	Pool	Time:	9:30 AM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:40 AM	EB
Total coliforms:	0/100mls	2/100mls	5/29/25	10:40 AM	EB
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	3:07 PM	SL
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/25	3:07 PM	SL
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	3:07 PM	SL

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2395

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b>Sample Collection</b>	
Facility Name:	Parkside Estates	Date:	5/28/25
Address:	202 Ketchum Court Cannonsburg, PA 15317	Time:	3:07 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

  

		<b>Sample Final Analysis</b>	
Matrix:	Recreational Water	Date:	5/31/25
Source Type:	Pool	Time:	9:30 AM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:40 AM	EB
Total coliforms:	0/100mls	2/100mls	5/29/25	10:40 AM	EB
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	3:07 PM	SL
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/25	3:07 PM	SL
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	3:07 PM	SL

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor