



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N - 1**

**Lab# 369**

**Customer**

Facility Name: Towne Place Suites

Address: Westside Square Dr.  
Mercer, PA 16137

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 1/12/26

Time: 1:30 PM

Method: Grab

**Sample Final Analysis**

Date: 1/15/26

Time: 12:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/13/26	12:00 PM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/13/26	12:00 PM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/12/26	5:22 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	1/12/26	1:30 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	1/12/26	1:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/12/26	1:30 PM	BH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)