



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 172**

**Customer**

**Facility Name:** Homewood Suites  
**Address:** 3000 Horizon Vue Dr.  
Cannonsburg, PA 15317

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 12/22/25  
**Time:** 11:18 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/25/25  
**Time:** 10:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/23/25 10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/23/25 10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/22/25 5:20 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/23/25 1:00 PM	JC	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	12/22/25 11:18 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/22/25 11:18 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/22/25 11:18 AM	GR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)