Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# **2377**

Customer		*Sample Collection*	
Facility Name:	Oakmont C.C.	*Date:*	7/22/25
		Time:	2:30 PM
Address:	1233 Hulton Road	*Method:*	Grab
	Oakmont, PA 15139		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	7/25/25
		Time:	10:00 AM
Source Type:	Shallow End	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	2:30 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	2:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	2:30 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# **2377**

Customer		***Sample Collection***

Facility Name: Oakmont C.C.

Address: 1233 Hulton Road
Oakmont, PA 15139

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection
Date: 7/22/25
Time: 2:30 PM
Method: Grab

Sample Final Analysis
Date: 7/25/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	2:30 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	2:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	2:30 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor