



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2059**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Bright Oaks*  
*Address: 600 N. Branch Road*  
*Oakdale, PA 15071*

*Date: 7/8/25*  
*Time: 12:15 PM*  
*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*  
*Source Type: Pool*

*Date: 7/11/25*  
*Time: 9:00 AM*  
*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:00 AM	EB SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:00 AM	EB SM 9222B
Standard plate count:	5700/ml	200/ml	7/8/25	4:30 PM	EB SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	12:15 PM	ZS DPD
Chlorine:	6.0 mg/l	1.0 - 5.0 mg/l	7/8/25	12:15 PM	ZS DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	12:15 PM	ZS Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2059**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Bright Oaks*

*Date: 7/8/25*

*Address: 600 N. Branch Road*  
*Oakdale, PA 15071*

*Time: 12:15 PM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 7/11/25*

*Source Type: Pool*

*Time: 9:00 AM*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/9/25	10:00 AM	EB SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:00 AM	EB SM 9222B
Standard plate count:	5700/ml	200/ml	7/8/25	4:30 PM	EB SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	12:15 PM	ZS DPD
Chlorine:	6.0 mg/l	1.0 - 5.0 mg/l	7/8/25	12:15 PM	ZS DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	12:15 PM	ZS Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor