



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2173**

**Customer**

Facility Name: *Edgeworth Club*  
Address: *511 East Drive*  
*Sewickley, PA 15143*

Matrix: *Recreational Water*

Source Type: *Baby Pool*

**Sample Collection**

Date: *8/13/25*  
Time: *12:45 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *8/15/25*  
Time: *4:00 PM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	3:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	3:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/13/25	3:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/13/25	12:45 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/13/25	12:45 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/13/25	12:45 PM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2173**

**Customer**

Facility Name: *Edgeworth Club*  
Address: *511 East Drive*  
*Sewickley, PA 15143*

Matrix: *Recreational Water*

Source Type: *Baby Pool*

**Sample Collection**

Date: *8/13/25*  
Time: *12:45 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *8/15/25*  
Time: *4:00 PM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	3:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	3:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/13/25	3:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/13/25	12:45 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/13/25	12:45 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/13/25	12:45 PM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor