

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 S-15

Lab# 2142

Customer

Facility Name:

Cranmoor Condominium

Address:

163 Roscommon Place Canonsburg, PA 15317

Matrix:

Recreational Water

Source Type:

Pool

Sample Collection

Date: Time: 8/5/25 11:17 AM

Method:

Grab

Sample Final Analysis

Date: Time: 8/8/25 8:30 AM

Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	11:17 AM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:17 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:17 AM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

anobie Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 S-15

Lab# 2142

Customer

Facility Name:

Cranmoor Condominium

Address:

163 Roscommon Place Canonsburg, PA 15317

Matrix:

Recreational Water

Source Type:

Pool

Sample Collection

Date: Time: 8/5/25 11:17 AM

Method:

Grab

Sample Final Analysis

Date: Time: 8/8/25 8:30 AM

Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	11:17 AM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:17 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:17 AM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

anobie Smith

Andre Smith, Lead Supervisor