



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2292

Customer

Facility Name: Jack Stack
Address: 600 Brighton Woods Rd.
Pittsburgh, PA 15212

Sample Collection

Date: 8/25/25
Time: 8:38 AM
Method: Grab

Sample Final Analysis

Date: 8/28/25
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/25 9:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25 9:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25 3:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/25/25 8:38 AM	CM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/25/25 8:38 AM	CM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25 8:38 AM	CM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor