



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM**

**Lab# 2608**

C2

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Yards @ 3 Crossings*

*Address:*              *2645 Railroad St.*  
                              *Pittsburgh, PA 15222*

*Matrix:*                *Recreational Water*

*Source Type:*        *Spa*

**Sample Collection**

*Date:*                    *9/16/25*

*Time:*                  *10:05 AM*

*Method:*                *Grab*

**Sample Final Analysis**

*Date:*                    *9/19/25*

*Time:*                  *9:00 AM*

*Analyst:*                *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/0/00	10:30 AM	JC	SM 9222G

Total coliforms:	0/100mls	2/100mls	1/0/00	10:30 AM	JC	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	0/ml	200/ml	1/0/00	5:45 PM	AS	SM 9215B
-----------------------	------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	9/17/25	10:00 AM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/16/25	10:05 AM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	9/16/25	10:05 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/16/25	10:05 AM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor