



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 111**

**Customer**

Facility Name: Greenfield Elementary

Address: 1 Alger St.  
Pittsburgh, PA 15207

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 10/27/25

Time: 12:35 PM

Method: Grab

**Sample Final Analysis**

Date: 10/30/25

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	10/28/25	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	10/28/25	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	A	10/27/25	5:15 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	8.0 SU	E	10/27/25	12:35 PM	MM	DPD
Chlorine:	4.0 mg/l	B	10/27/25	12:35 PM	MM	DPD
Turbidity:	1 NTU	A	10/27/25	12:35 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor