



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 328**

**Customer**

*Facility Name:* Washington & Jefferson

*Address:* 60 S. Lincoln St.  
Washington, PA 15301

*Matrix:* Recreational Water

*Source Type:* Dive Pool

**Sample Collection**

*Date:* 9/22/25

*Time:* 9:12 AM

*Method:* Grab

**Sample Final Analysis**

*Date:* 9/25/25

*Time:* 10:00 AM

*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/23/25	12:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/23/25	12:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/22/25	12:00 AM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/22/25	12:00 AM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/22/25	12:00 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/22/25	12:00 AM	GR	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor