



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2525

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Address:	Matrix:	<b>Sample Collection</b>		
			Date:	Time:	Method:
Torrent of Upper St. Clair	2565 Boyce Plaza Rd. Upper St. Clair, PA 15241	Recreational Water	6/16/25	2:01 PM	Grab
Pool					

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/17/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	11:30 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	6/16/25	6:00 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	2:01 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:01 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:01 PM	AF	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2525

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Address:	Matrix:	<b>Sample Collection</b>		
			Date:	Time:	Method:
Torrent of Upper St. Clair	2565 Boyce Plaza Rd. Upper St. Clair, PA 15241	Recreational Water	6/16/25	2:01 PM	Grab
Pool					

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/17/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	11:30 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	6/16/25	6:00 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	2:01 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:01 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:01 PM	AF	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor