



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206 **PPS**
(412) 661- 7665
Laboratory Analysis Report **Lab# 213**

Lab ID No. 02-04041

Customer

Facility Name: *Langley High School*

Address: *2940 Sheradan Blvd.
Pittsburgh, PA 15204*

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *1/20/26*

Time: *7:36 AM*

Method: *Grab*

Sample Final Analysis

Date: *1/23/26*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	1/21/26	10:00 AM	SL SM 9222G
Total coliforms:	0/100mls	A	1/21/26	10:00 AM	SL SM 9222B
Standard plate count:	0/ml	A	1/20/26	5:30 PM	SL SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method
pH:	7.6 SU	A	1/20/26	7:36 AM	MM DPD
Chlorine:	2.0 mg/l	B	1/20/26	7:36 AM	MM DPD
Turbidity:	1 NTU	A	1/20/26	7:36 AM	MM Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)