



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 141

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Heinz House	Date:	12/1/25			
Address:	1 Heinz St. Pittsburgh, PA 15212	Time:	1:20 PM			
Matrix:					<u>Sample Final Analysis</u>	
	Recreational Water	Date:	12/4/25			
Source Type:	Pool Shallow	Time:	10:00 AM			
Analyst:	AS					
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	12/2/25	9:35 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/2/25	9:35 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/1/25	4:15 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	12/1/25	1:20 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/1/25	1:20 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/1/25	1:20 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor