

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 C-11

Lab# 067

SM 9230C

AΗ

CustomerSample CollectionFacility Name:Cork FactoryDate: 6/3/25

Address: Time: 8:50 AM
Address: 2349 Rail Road St. Method: Grab
Pittsburgh, PA 15222

Matrix: Recreational Water Sample Final Analysis

Date: 6/6/25

2/100mls

Source Type: Spa Time: 9:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit Method **Analyst Incubation Date/Time** Escherichia Coli: Absent Absent 6/4/25 11:00 AM ΕB SM 9222G Total coliforms: 0/100mls 2/100mls 6/4/25 11:00 AM ΕB SM 9222B Standard plate count: 0/ml 200/ml 6/3/25 5:15 PM EΒ SM 9215B **Additional Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time**

6/4/25

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
рН:	8.0 SU	7.2 - 7.8 SU	6/3/25	8:50 AM	LM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/3/25	8:50 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	8:50 AM	LM	Visual

Sample comments

Fecal Streptococcus

0/100mls

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith

12:00 PM



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 C-11

Lab# 067

SM 9230C

AΗ

CustomerSample CollectionFacility Name:Cork FactoryDate: 6/3/25

Address: Time: 8:50 AM
Address: 2349 Rail Road St. Method: Grab
Pittsburgh, PA 15222

Matrix: Recreational Water Sample Final Analysis

Date: 6/6/25

2/100mls

Source Type: Spa Time: 9:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit Method **Analyst Incubation Date/Time** Escherichia Coli: Absent Absent 6/4/25 11:00 AM ΕB SM 9222G Total coliforms: 0/100mls 2/100mls 6/4/25 11:00 AM ΕB SM 9222B Standard plate count: 0/ml 200/ml 6/3/25 5:15 PM EΒ SM 9215B **Additional Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time**

6/4/25

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
рН:	8.0 SU	7.2 - 7.8 SU	6/3/25	8:50 AM	LM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/3/25	8:50 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	8:50 AM	LM	Visual

Sample comments

Fecal Streptococcus

0/100mls

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith

12:00 PM