



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2304

Customer

Facility Name: *Kennywood Park*

Address: *4800 Kennywood Blvd.
West Mifflin, PA 15122*

Matrix: *Recreational Water*

Source Type: *PGH Plunge*

Sample Collection

Date: *8/5/25*

Time: *1:15 PM*

Method: *Grab*

Sample Final Analysis

Date: *8/8/25*

Time: *8:30 AM*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/6/25 | 3:30 PM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/6/25 | 3:30 PM | AH | SM 9222B |
| Standard plate count: | 120/ml | 200/ml | 8/5/25 | 6:45 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.9 SU | 7.2 - 7.8 SU | 8/5/25 | 1:15 PM | ZS | DPD |
| Chlorine: | 6.0 mg/l | 1.0 - 5.0 mg/l | 8/5/25 | 1:15 PM | ZS | DPD |
| Turbidity: | 3 NTU | 1 - 2 NTU | 8/5/25 | 1:15 PM | ZS | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2304

Customer

Facility Name: *Kennywood Park*

Address: *4800 Kennywood Blvd.*
West Mifflin, PA 15122

Matrix: *Recreational Water*

Source Type: *PGH Plunge*

Sample Collection

Date: *8/5/25*

Time: *1:15 PM*

Method: *Grab*

Sample Final Analysis

Date: *8/8/25*

Time: *8:30 AM*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/6/25 | 3:30 PM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/6/25 | 3:30 PM | AH | SM 9222B |
| Standard plate count: | 120/ml | 200/ml | 8/5/25 | 6:45 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.9 SU | 7.2 - 7.8 SU | 8/5/25 | 1:15 PM | ZS | DPD |
| Chlorine: | 6.0 mg/l | 1.0 - 5.0 mg/l | 8/5/25 | 1:15 PM | ZS | DPD |
| Turbidity: | 3 NTU | 1 - 2 NTU | 8/5/25 | 1:15 PM | ZS | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor