



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 2120**

**Customer**

Facility Name: Club at Nevillewood  
Address: 1000 Nevillewood Drive  
Presto, PA 15142

Matrix: Recreational Water

Source Type: Small Pool

**Sample Collection**

Date: 8/18/25  
Time: 11:02 AM  
Method: Grab

**Sample Final Analysis**

Date: 8/21/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/25	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	10:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/18/25	11:02 AM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/18/25	11:02 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	11:02 AM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor