



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-10**

**Lab# 185**

**Customer**

Facility Name: Jewish Community Center

Address: 345 Kane Boulevard  
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 7/28/25

Time: 11:17 AM

Method: Grab

**Sample Final Analysis**

Date: 7/31/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	11:17 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:17 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:17 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-10**

**Lab# 185**

**Customer**

Facility Name: Jewish Community Center

Address: 345 Kane Boulevard  
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 7/28/25

Time: 11:17 AM

Method: Grab

**Sample Final Analysis**

Date: 7/31/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	11:17 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:17 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:17 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor