



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 132**

**Customer**

Facility Name: Hampton Inn - Uniontown

Address: 698 West Main Street  
Uniontown, PA 15401

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 10/27/25

Time: 1:20 PM

Method: Grab

**Sample Final Analysis**

Date: 10/30/25

Time: 12:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/28/25	11:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/25	11:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/27/25	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.2 SU	7.2 - 7.8 SU	10/27/25	1:20 PM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/27/25	1:20 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/27/25	1:20 PM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor