



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2719**

**Customer**

Facility Name: Meeder Flats  
Address: 1000 Strand Road  
Cranberry, PA 16066

Matrix: Recreational Water  
Source Type: Spa

**Sample Collection**

Date: 6/2/25  
Time: 1:23 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/5/25  
Time: 9:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25 9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25 9:15 AM	EB	SM 9222B
Standard plate count:	80/ml	200/ml	6/2/25 3:17 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/3/25 11:30 AM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25 1:23 PM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/2/25 1:23 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25 1:23 PM	ZR	Visual

**Sample comments**

*Anaë Smith*

( When exceeding reporting limit pool or spa is unfit)



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2719**

**Customer**

Facility Name: Meeder Flats  
Address: 1000 Strand Road  
Cranberry, PA 16066

Matrix: Recreational Water  
Source Type: Spa

**Sample Collection**

Date: 6/2/25  
Time: 1:23 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/5/25  
Time: 9:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25 9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25 9:15 AM	EB	SM 9222B
Standard plate count:	80/ml	200/ml	6/2/25 3:17 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/3/25 11:30 AM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25 1:23 PM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/2/25 1:23 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25 1:23 PM	ZR	Visual

**Sample comments**

*Anaë Smith*

( When exceeding reporting limit pool or spa is unfit)