



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 013**

**Customer**

**Facility Name:** *Bairel Center*  
**Address:** *2565 Nicholson Road*  
*Sewickley, PA 15143*

**Matrix:** *Recreational Water*  
**Source Type:** *Deep End*

**Sample Collection**

**Date:** *6/3/25*  
**Time:** *3:37 PM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/6/25*  
**Time:** *9:30 AM*  
**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/4/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	5:45 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	6/3/25	3:37 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/3/25	3:37 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	3:37 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 013**

**Customer**

**Facility Name:** *Bairel Center*  
**Address:** *2565 Nicholson Road*  
*Sewickley, PA 15143*

**Matrix:** *Recreational Water*  
**Source Type:** *Deep End*

**Sample Collection**

**Date:** *6/3/25*  
**Time:** *3:37 PM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/6/25*  
**Time:** *9:30 AM*  
**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/4/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	5:45 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	6/3/25	3:37 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/3/25	3:37 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	3:37 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor